


UTILITY POSTOP LANTERN WITH CUTOFF OPTICS  
HOLOPHANE #PTU-100HP-MC-M-X-G3-S-C-LAMP

FOR COLOR CHANGE "X" TO:  
B FOR BLACK  
Z FOR BRONZE  
N FOR GREEN

FOR 20A GFI RECEPTACLE  
ADD # FGIUS-20  
(OPTIONAL - SEE PLAN)



ANCHORAGE  
DETAIL

CHARLESTON FLUTED POLE  
HOLOPHANE #CH14.5F5/U16-CA-X

FOR COLOR CHANGE "X" TO:  
BKH FOR BLACK  
DBH FOR BRONZE  
DGH FOR DARK GREEN

BOLT CIRCLE 10" TO 12"  
3/4" ANCHOR BOLTS

APPROVED LIGHT BASE FOUNDATION:  
MILLERBERND # 490A111 SCREW-IN  
ANCHOR BASE, OR MN/DOT CONCRETE  
LIGHT BASE DESIGN E MOD  
(SEE PLAN FOR DETAIL)



CITY OF EDINA  
ENGINEERING  
& PUBLIC  
WORKS  
DEPTS.

POSTOP LANTERN

*Wayne J. Schuler*  
APPROVED: CITY ENGINEER

REVISED:  
01-08

STANDARD  
PLATE

618